Via dell'Industria 12-12/A, 42025 CAVRIAGO (RE), Italy CF/PI/Iscr.Reg.Imprese RE 00303000350 VAT IT 00303000350 REA 90637 Telefono/Phone +390522942641 / +390522941172 www.camlogic.it – email: camlogic@camlogic.it

UK DECLARATION OF CONFORMITY



Manufacturer	CAMLOGIC S.R.L. Via dell'Industria 12-12/A, 42025 Cavriago (RE)
--------------	--------------------------------------------------------------------

We hereby declare as manufacturer that the products:

Product	Rotary point level switch		MN21 series
Year of production	2025	Serial number *1	

Complies with the Directives listed below:

Relevant statutory requirements	Relevant designated standards
S.I. 2016 No. 1101	BS EN 61010-1:2010+A1:2019
S.I. 2016 No. 1091	BS EN 61326-1:2013
S.I. 2012 No. 3032	-
Optional: S.I. 2016 No. 1107	BS EN IEC 60079-0:2018 BS EN 60079-31:2014

Additional information for equipment with ATEX approval:

EU-Type Examination Certificate No. Issued by	TÜV IT 23 ATEX 140 X TÜV Italia S.r.l. (Notified body N.0948)
Protection type	II 1/2 Ex ta/tb IIIC T85°C IP65 Da/Db

(Quality assurance / Issued by	TÜV IT 17 ATEX 001 Q TÜV Italia S.r.l. (Notified body N.0948)

This declaration of conformity is issued under the sole responsibility of the manufacturer.

The manufacturer declares that the product complies with the requirements of the latest editions of the standards. The changes of the latest editions have been checked and do not affect the product.

All related supporting documentation is available at the Company.



Cavriago, 06.01.2025 G. Guazzetti (CEO)

Validity: until cancelled by reissue

^{*1} Available on request from the Company

Rotary level switch MN21	0600_0029_00-02 - 06.01.2025	1 /of 1
--------------------------	------------------------------	----------------